



COMPLIANCE
"Your Challenges...Our Strengths"

Electrical Testing - Wrong categorisation of deviation on an EICR

Question - When is a C3 deviation not a C3 deviation?

Answer - When your dodgy contractor needs more work!

EICR - C1, C2, C3 deviations explained

We are fed up of seeing electrical deviations from BS7671 wrongly categorised when clients have paid for an Electrical Installation Condition Report (EICR) from a contractor that they believe to be reputable.

We are regularly asked to quote electrical remedial work for clients who have had an EICR completed by what they believed to be a reputable contractor and what we see can sometimes beggar belief.

We all know that a C3 deviation is often not a priority and that clients often do not authorise their remedy whereas C1 and C2 deviations usually are authorised by clients.

It is a betrayal of trust to knowingly wrongly categorise a deviation on a EICR. To do so from a position of ignorance is equally unacceptable.

Perhaps I should open a rogue's gallery.... Let me have your thoughts?



ISO 9001 • ISO 14001
OHSAS 18001