



IEE recommends the maximum time between having an Electrical Installation Condition Report to be as follows;

Type of premises	Time before next test
<b>Educational premises</b>	5 years
<b>Commercial premises</b>	max 5 years
<b>Industrial premises</b>	max 3 years
<b>Domestic</b>	max 10 years or at change of occupancy
<b>Shops and Offices</b>	max 5 years
<b>Residential</b>	max 5 years or at change of occupancy
<b>Hotels and Public Houses</b>	max 5 years
<b>Community Centres/Village Halls</b>	max 5 years
<b>Churches</b>	max 5 years
<b>Places of public entertainment and theatres</b>	max 3 years
<b>Leisure complexes (excluding swimming pools)</b>	max 3 years
<b>Swimming pools</b>	max 1 years
<b>Launderettes</b>	max 1 years
<b>Construction site/temporary installations</b>	every 3 months